



Department of Public Safety – Fire Division  
500 City Center Drive  
Rohnert Park, CA 94928  
Phone: (707) 584-2641



## **REQUIREMENTS FOR THE OPERATION OF A FIREWORKS STAND IN THE CITY OF ROHNERT PARK**

The applicant agrees to comply with the following requirements:

- (1) No person shall fire, discharge, set off, or use any fireworks of any kind other than Safe and Sane within the City. No parent, Guardian, or other person having legal care or custody of any minor child shall allow such child to violate the provisions of this section.
- (2) The hours of operation for the fireworks stand shall be from 8:00 AM on the 30th of June and ending at 9:00 p.m. on July 4th of that same year.
- (3) All Fireworks stands will be inspected by the local Fire Department prior to the start of sales. Fire Inspections will be held on or before June 28th, call 584-2641 for an appointment.
- (4) The following permits and / or Licenses shall be posted in the fireworks stand: California State Fire Marshal's Retail License, City of Rohnert Park Planning Department temporary Use Permit, and the City of Rohnert Park Fire Department Permit. Copies are to be provided with application for the fireworks stand.
- (5) A copy of Proof of Insurance, \$100,000 / \$300,000 public liability, \$50,000 property damage and \$2,000,000 product liability insurance coverage with riders attached to the policies designating the City of Rohnert Park, its Officers, Agents, and employees as additional insured there under must be filed with the City of Rohnert Park Fire Department. No policy will be acceptable which contains a provision allowing a deductible amount.
- (6) Each stand must have at least two exits and in no case shall the distance between the exits exceed twenty-four (24) feet. No stand shall have a floor area in excess of 350 sq. ft. Exit doors shall be not less than twenty-four (24) inches wide and six (6) ft. in height and shall swing in the direction of exit travel.
- (7) NO SMOKING in or about the stands— Stands are to be posted with "NO SMOKING " signs in Red lettering at least four inches in height. Such signs shall be visible to every person working in the stand and every customer while being served.
- (8) No fireworks stand shall be located within 25 ft. of another building, within 25 ft. of a generator, within 5 ft. of a curb line, nor within 100 feet of any gasoline pump.
- (9) No vehicles shall be parked within 25 ft. of the fireworks stand. Define area of NO PARKING with cones, ropes, etc.
- (10) No one under the age of eighteen (18) years of age may work or sell in the fireworks stand.
- (11) No fireworks of any kind shall be sold to anyone under the age of Eighteen (18) years of age. 15.28-7804.3 RPMC.

- (12) Minimum of one fire extinguisher rated 2A10BC, with current State Fire Marshall's tag attached shall be mounted inside the stand in open view and near exit.
- (13) Area in and around stand to be cleared of vegetation and combustible material for 25 ft. in all directions.
- (14) All unsold stock shall be removed from the stand and located in an approved storage area immediately after the close of business on each day of operation.
- (15) All retail sales of state-approved fireworks shall be permitted only from within a temporary stand. Sales from any other buildings or structures is hereby prohibited.
- (16) All unsold stock of fireworks in the hands of the permittee after 9:00 p.m. on the 4th day of July shall be returned to the wholesaler/distributor within 24 hours and removed from the City of Rohnert Park within ten (10) days.
- (17) No person shall light, caused to be lighted or permit to be lighted any state-approved fire works or combustible material within fifty (50) feet of any state-approved fireworks stand.
- (18) Written authorization from the property owner or his designee is required giving permission to sell Safe and Sane Fireworks at the designated location (Form to be on file with the Fire Department prior to file inspection).
- (19) Fireworks are to be stored in approved containers (truck or metal containers or trailers with no source of ignition) at an approved location designated by the Fire Department. You shall provide 24– hour security on fireworks.

\_\_\_\_\_  
Name of Organization

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date